

PROCEEDINGS FROM THE BOARD OF SUPERVISORS OF SEWERAGE DISTRICT No. 1 OF IBERIA
PARISH, LOUISIANA, TAKEN AT A REGULAR MEETING HELD ON TUESDAY, AUGUST 26, 2025.

The Board of Supervisors of Sewerage District No. 1 of Iberia Parish, Louisiana, met in Regular Session at the Iberia Parish Sewerage District No. 1 office, 2617 Northside Road on Tuesday, August 26, 2025, at four o'clock p.m.

Gage Guidry called the meeting to order with the following members present: Gage Guidry, Eddie Chretien, William Labauve, and Sy Bodin.

Also, present were Chandler Staples, Staples Engineering, Darius Colar, Statewide Electrical Services, LLC, and Scott Landry, Statewide Electrical Services, LLC.

It was moved by Chretien, seconded by Labauve, that the Board of Supervisors of Sewerage District No. 1 does hereby approve the minutes taken at the Regular Meeting held on July 29, 2025.

This motion having been submitted to a vote; the vote thereon was as follows:

YEAS: Gage Guidry, Eddie Chretien, William Labauve, Sy Bodin

NAYS: None

ABSENT: None

And the motion was declared adopted on this the 26th day of August, 2025.

A report was given by Scott Landry of Statewide Electrical Services, LLC, on the operation and maintenance of Plant 3 for the month of August 2025. Preventative maintenance was performed in several areas of the plant. Clarifier #1 was drained and cleaned for yearly inspection. The motor belt for the belt press was replaced allowing for wasting to resume. One hundred-seventy thousand (170,000) gallons of sludge have been wasted from July 29 through August, 21, 2025.

A report from Darius Colar with Statewide Electrical Services, LLC was reviewed for the month of August 2025 for the operation and maintenance of the District's field. All work for the month was primarily routine operation and maintenance. A force main was repaired at La Belle Colline Lift Station, Jefferson Island Road and Grand Prairie Blvd as well as a sewer leak on Snap Dragon. New pumps were installed at Belle Terre and Arco lift stations . The vacuum truck was used at Turner, Troy Road, and Lucky Lane lift stations.

A report from Staples Engineering: Highway 90 project has started. The UL/ NIRC documents were sent the Parish for review and approval late August.

The Director gave his report. First Solar is now in its warranty period. The subdivision project funded by the Water Sector Grant has been issued a notice to proceed, with construction expected to begin on September 8, 2025. Additionally, contracts for the Tete Bayou Improvement Project, also funded by the Water Sector Grant, have been finalized and are ready for signing.

Having no other business, it was moved by Bodin, seconded by Chretien, that the Board of Supervisors of Sewerage District No. 1 does hereby adjourn.

This motion having been submitted to a vote; the vote thereon was as follows:

YEAS: Gage Guidry, Eddie Chretien, William Labauve, Sy Bodin

NAYS: None

ABSENT: None

And the motion was declared adopted on this the 26th day of August, 2025.

/s/signed

Brad Cradeur, Executive Director