PROCEEDINGS FROM THE BOARD OF SUPERVISORS OF SEWERAGE DISTRICT # 1 OF IBERIA PARISH, LOUISIANA, TAKEN AT A REGULAR MEETING HELD ON TUESDAY, NOVEMBER 28, 2023.

The Board of Supervisors of Sewerage District No. 1 of Iberia Parish, Louisiana, met in Regular Session at the Iberia Parish Sewerage District No. 1 office, 2617 Northside Road on Tuesday, November 28, 2023, at four o'clock p.m.

Kasey Thibodeaux. called the meeting to order with the following members present: William Labauve, Eddie Chretien, and Larry Darby, Jr.

Also, present were Chandler Staples, Staples Engineering and Neal Swain, Statewide Electrical Services, LLC.

It was moved by Chretien, seconded by Labauve, that the Board of Supervisors of Sewerage District No. 1 does hereby approve the minutes taken at the Regular Meeting held on October 24, 2023.

This motion having been submitted to a vote; the vote thereon was as follows:

YEAS: Kasey Thibodeaux, William Labauve, Eddie Chretien, Larry Darby Jr.

NAYS: None

ABSENT: None

And the motion was declared adopted on this the 28th day of November 2023.

A report was given by Neal Swain of Statewide Electrical Services, LLC, on the operation and maintenance of Plant 3 for the month of November 2023. He reported that all has been routine for the most part. All major components of the daily operations and maintenance are functioning properly. A new vacuum pump and composite auto sampler were installed in the lab. A new regulator was installed for the chlorination system.

A report from Statewide Electrical Services, LLC was reviewed for the month of November 2023 for the operation and maintenance of the District's field. We are still having issues with wipes at a few lift stations. Repairs were made to a force main in a cane field East of Mullins Drive, manhole on Belle Place Oliver Road was also repaired. A new motor for the blower was installed at the Oile Center Drive Lift Station and a new liberty pump was installed at the Chart Lift Station at the Port of Iberia. All other work for the month was primarily routine operation and maintenance.

A report from Staples Engineering; Chandler reported that GIS is presently at 369 manholes completed. The District has purchased a trimble device in order to continue the manhole mapping for the Parish's GIS system. All current projects are on schedule.

Having no other business, it was moved by Chretien, seconded by Darby, that the Board of Supervisors of Sewerage District No. 1 does hereby adjourn.

YEAS: Kasey Thibodeaux, William Labauve, Eddie Chretien, Larry Darby Jr. NAYS: None ABSENT: None And the motion was declared adopted on this the 28th day of November 2023.

_/s/signed____

Brad Cradeur, Executive Director