

PROCEEDINGS FROM THE BOARD OF SUPERVISORS OF SEWERAGE DISTRICT NO. 1 OF IBERIA PARISH, LOUISIANA, TAKEN AT A REGULAR MEETING HELD ON TUESDAY, JULY 28, 2026

The Board of Supervisors of Sewerage District No. 1 of Iberia Parish, Louisiana, met in Regular Session at the Iberia Parish Sewerage District No. 1 office, 2617 Northside Road, on Tuesday, July 28, 2026, at four o'clock p.m.

Gage Guidry called the meeting to order with the following members present: Gage Guidry, Eddie Chretien, William Labauve, Sy Bodin, and Larry Darby, Jr.

Also, present were Barry Segura, Scott Landry, and Darius Colar, Statewide Electrical Services, LLC.

It was moved by Darby, seconded by Chretien, that the Board of Supervisors of Sewerage District No. 1 does hereby approve the minutes taken at the Regular Meeting held on June 23, 2026.

This motion having been submitted to a vote, the vote thereon was as follows:

YEAS: Gage Guidry, Eddie Chretien, William Labauve, Sy Bodin, Larry Darby, Jr.

NAYS: None

ABSENT: None

And the motion was declared adopted on this the 28th day of July 2026.

A report from Scott Landry, Statewide Electrical Services, LLC, was presented regarding the operation and maintenance of Plant No. 3 for the month of July 2026. Preventative maintenance was performed on digester blowers, EPW pumps and motors, Clarifier No. 2 gearbox and motor, mechanical bar screen, and bridge aerators. The pond water level is at the aerator anchors. The digester blower remains out of service with a replacement on order and expected before August 1. A new EPW pressure gauge was installed and is functioning properly. Digester cleanup is ongoing.

A report from Darius Colar, Statewide Electrical Services, LLC, was presented regarding the operation and maintenance of the District's field for the month of July 2026. Work for the month consisted primarily of routine operations and maintenance. At the Delcambre High School Lift Station, both pumps were replaced after being found burned. At Thibodeaux's Trailer Park, a sewer gravity line near the sewer pond was repaired. The new UL Lift Station was installed. At 5303 Old Spanish Trail, the existing pump was replaced with a new Liberty pump. The pump truck was utilized at the Iberia Parish Jail, Pennywise Lift Station, Port of Iberia-LA CAT, Lucky Lane, and Port of Iberia-Quick Stop.

A written report from Staples Engineering was received regarding the District's construction and engineering projects for the month of July 2026. The Hwy. 90 Sewerage Improvements Change Order No. 1 was completed on July 24, 2026. Work at the Progress Point Lift Station is awaiting electrical service from Cleco, with minor demolition and testing remaining on the original project. The UL Lift Station relocation project was started up on July 14, 2026, and sewer is now flowing through the new lift station. Demolition and salvage of the former lift station and lines are underway, and the substantial completion process has begun. GIS updates are continuing to include additional infrastructure and equipment.

The Director gave his report. He reported that a subdivision project progress meeting was scheduled for July 29, 2026, with the projects nearing completion. Plant No. 3 upgrades at the Tete Bayou facility continue, with construction of the chlorine building underway and additional materials still pending. He further reported that Andy Shealy is assisting with the contract for engineering services for the new wastewater treatment plant.

The Board discussed the Intergovernmental Agreement for shared sewer services between the City of New Iberia and Sewerage District No. 1 of Iberia Parish, which is scheduled to expire on September 1, 2026. The Board discussed the City's proposed rates for a five-year term. The Board's position was that the rate may increase during the five-year term but should remain fixed at the rate in effect at the end of the five-year term if the agreement continues on a month-to-month basis thereafter.

Having no other business, it was moved by Chretien, seconded by Labauve, that the Board of Supervisors of Sewerage District No. 1 does hereby adjourn.

This motion having been submitted to a vote, the vote thereon was as follows:

YEAS: Gage Guidry, Eddie Chretien, William Labauve, Sy Bodin, Larry Darby, Jr.

NAYS: None

ABSENT: None

And the motion was declared adopted on this the 28th day of July 2026.

/s/signed_____

Brad Cradeur, Executive Director